



NEWLOTHROP AREA PUBLIC SCHOOLS

New Lothrop Area Public Schools is accepting bids for the following:

FFA Barn Electrical

- Install 200 amp three phase panel board switch in Elementary panel.
- Install sub feed approximately 350' with 4 copper 3/0 THHN conductors in 2 ½" PVC SCH 40 conduit for underground and EMT conduit above ground.
- Provide additional spare 2 ½" PVC SCH 40 conduit for future wire.
- Install 200 amp 120/208 volt three phase panel in outbuilding and connect to underground sub feed.
- Include all permits

**** Any differences in specifications must be notated. ****

Please contact, Wayne Wright, Superintendent, at 810-638-5091 for specific details before submitting final bid.

Bids should be sent in a sealed envelope to:

New Lothrop Area Public Schools
Attn: Wayne Wright Superintendent
(Indicate "Barn Electrical")
9285 Easton Road
New Lothrop, MI 48460

Bids are due on Friday, May 16th, 2025 at 12:00 p.m. in the Superintendent's office.

Bids will not be accepted by fax or email.

Administrative Office

9285 Easton Road, Box 339
New Lothrop, MI 48460
810.638.5091
Fax: 810.638.7277

High School Office

9285 Easton Road, Box 339
New Lothrop, MI 48460
810.638.5054
Fax: 810.638.5057

Elementary School Office

9387 Genesee St., Box 279
New Lothrop, MI 48460
810.638.5026
Fax: 810.638.7289